

TESTED FOR: Avila Stone LLC
501 South Ave.
Donna, Texas 78537

PROJECT: Avila Stone-Plant Information
Donna, Texas

DATE: July 13, 2010


OUR REPORT NO.: 75100037-4

COMMENTS: On July 13, 2010, EarthCo representative, Rudy Martinez received a sample of Dark Granite material delivered by Mike Avila of Avila Stone. The Dark Granite Material was tested for resistance to Degradation of small-size coarse aggregate by abrasion and impact in the Los Angeles Machine in accordance with (ASTM C 131-06).

The results of the laboratory tests performed are as follows:

Sample Id.	Actual % Loss	Specification
Dark Granite	15.7	Max: 35 % Loss

Respectfully Submitted,
EarthCo, LLC



Cc: